Ydeevnedeklaration Bundfældningstank Type Graf Carat



1. Unique identification code of the product-type		Septic tank according to EN 12566-1
 Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4) 		Nominal sizes 2 (Carat S 2700), 3 (Carat S 3750), 4 (Carat S 4800), 6 (Carat S 6500) Larger tanks can be made by establishing two smaller in series Nominal size on tank nameplate Serial numbers on underground tank
3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer		Part of treatment for domestic wastewater
 Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5) 		Otto Graf GmbH Kunststofferzeugnisse Carl-Zeiss-Str. 2-6 79331 Teningen Germany
5. Name, registered trade name or registered trade mark and contact address of the importer into Denmark		BioKube A/S Centervej Syd 5 4733 Tappernøje
 System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V 		System 3
8. Declared performance		
	Performance	Test report No.
Hydraulic efficiency	99,79 % (2,15 g)	PIA2014-HWG-1404-1020-01
Watertightness	Passed	PIA2014-WD/NC-1404-1020.02
Crushing resistance	Passed	PIA2008-ST-AT0804-1019 BES/N9902/PP/pp/09.142
Durability	Passed	PIA2008-ST-AT0804-1019e
Groundwater over outlet	Approved up to 1500 mm	System stabel with groundwater at groundlevel 1500 mm over outlet
Bouancy Control	Not required	No protection against updrift requirewd

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 7. This declaration of performance is issued under the sole responsibility of the importer in Denmark.

Signed for and on behalf of the importer by:

Peter Taamhoj

Peter Taarnhøj

Tappernøje 13-01-2018